DANGEROUS GOODS STORAGE SPECIALISTS

Phone: 1300 903 933

Email: office@wssa.com.au

Web: www.wssa.com.au



Flammable liquid safety cabinet for 205L drum

APPLICATION

For the safe and secure indoor storage of Class 3 flammable liquids and combustible liquids.

FEATURES

- In-built roller base module for 205 litre drum
- Double wall construction with 40mm thermal barrier
- · Vent ports with integral flash arrestors fitted on each side
- Self-closing door with stainless steel, three point bullet self-latching system
- Adjustable hydraulic door closure
- Flush mount handle and key lock
- · Continuous piano hinges on doors deliver smooth closure
- One adjustable shelf plus drum roller base module (fixed)
- Internal spill containment bund with suspended perforated floor
- Durable UV-stabilised powder coat finish
- Grounding connector enables earthing if required
- Adjustable screw-in feet for optional elevation
- Safety and warning signage applied in accordance with Australian Standards





SPECIFICATIONS	
Product name	Flammable liquid safety cabinet
Code	FGC205V
Maximum storage capacity	250 litres
Construction material	Steel
Surface finish	UV-stabilised polyester powder
Paint colour	Yellow
Doors	1
Shelves (including roller base)	2
Shipping weight	163kg

MANUFACTURED TO MEET THE REQUIREMENTS OF	
AS1940-2017	The storage and handling of flammable and combustible liquids
AS1319-1994	Safety signs for the occupational environment
ADG CODE 7.5	Australian Dangerous Goods Code 2017 Edition 7.5
AS4506-2005	Metal finishing - Thermoset powder coatings

DIMENSIONS (W x D x H)		
External dimensions	810mm x 810mm x 1850mm	
Internal dimensions	700mm x 710mm x 1600mm	



Class 3: Flammable Liquids

Flammable liquids are liquids, or mixtures of liquids, or liquids containing solids in solution or suspension (for example, paints, varnishes, lacquers, etc., but not including substances otherwise classified on account of their dangerous characteristics) which give off a flammable vapour at temperatures of not more than 60 °C, closed-cup test, or not more than 65.6 °C, open-cup test, normally referred to as the flash point.

Referenced from the Australian Dangerous Goods Code, 2017, Edition 7.5