

Flammable Liquids dangerous goods store - 4x drums / single pallet (850L)

APPLICATION

For the safe and secure outdoor storage of Class 3 flammable liquids and combustible liquids.

FEATURES

- Store up to 4x 205 litre drums individually or on a pallet
- Heavy duty fabricated galvanised steel construction
- Two-coat protective finish for outdoor use.
- Rear sloping roof with gutter to allow rain water run-off.
- Single 270° opening door with ISO locking bar.
- Fitted with earth lug and supplied with an earth stake for site install if required.
- Ventilated in accordance with Australian Standards.
- Safety and warning signage applied in accordance with Australian Standards.
- Manufactured in Australia to meet the requirements of AS1940-2017 "The storage and handling of flammable and combustible liquids".



** Image for purpose of display. Flammable liquids storage cabinet will be fitted with class 3 dangerous goods signage*

SPECIFICATIONS

| | |
|--------------------------|---|
| Product name | Flammable liquids dangerous goods store |
| Code | FLC850P-OD |
| Maximum storage capacity | 850 litres |
| Construction material | Galvanised steel |
| External surface finish | Epoxy powder undercoat + UV-stabilised polyester powder topcoat |
| Colour | Yellow |
| Doors | 1 |
| Shelves (including base) | 1 |
| Shipping weight | 380kg |
| Bund capacity | 254 litres |

DIMENSIONS (W x D x H)

| | |
|----------------------|--------------------------|
| External dimensions | 1546mm x 1446mm x 1700mm |
| Internal dimensions* | 1210mm x 1200mm x 1297mm |

* Useable internal dimensions



Class 3: Flammable Liquids

Flammable liquids are liquids, or mixtures of liquids, or liquids containing solids in solution or suspension (for example, paints, varnishes, lacquers, etc., but not including substances otherwise classified on account of their dangerous characteristics) which give off a flammable vapour at temperatures of not more than 60 °C, closed-cup test, or not more than 65.6 °C, open-cup test, normally referred to as the flash point.

Referenced from the Australian Dangerous Goods Code, 2017, Edition 7.5

MANUFACTURED TO MEET THE REQUIREMENTS OF

| | |
|--------------|---|
| AS1940-2017 | The storage and handling of flammable and combustible liquids |
| AS1319-1994 | Safety signs for the occupational environment |
| ADG CODE 7.5 | Australian Dangerous Goods Code 2017 Edition 7.5 |
| AS2312-2014 | Guide to the protection of structural steel against atmospheric corrosion by the use of protective coatings |