## DANGEROUS GOODS STORAGE SPECIALISTS

Phone: 1300 903 933

Email: office@wssa.com.au

Web: www.wssa.com.au



# Organic peroxides safety cabinet - 60L storage capacity



#### **APPLICATION**

For the safe and secure indoor storage of Class 5, Division 5.2 organic peroxides.

#### **FEATURES**

- Double wall construction with 40mm thermal barrier
- Vent ports with integral flash arrestors fitted on each side
- Two self-closing doors with pressure release catches
- Adjustable hydraulic door closure
- Flush mount handle
- Continuous piano hinges on doors deliver smooth closure
- One adjustable shelf plus fixed base shelf
- Internal spill containment bund with suspended perforated floor
- Durable UV stabilised thermosetting polyester powder coat finish
- Grounding connector enables earthing if required
- Adjustable screw-in feet for optional elevation
- Safety and warning signage applied in accordance with Australian Standards.



DANGER	
NO SMOKING	(0
orienae orienae \$3	
NO IGNITION SOURCES	
ISTONE MAXIMUM COMETY OUTURE:	

SPECIFICATIONS	
Product name	Organic peroxide safety cabinet
Code	OPC60
Maximum storage capacity	60 litres
Construction material	Steel
Surface finish	UV-stabilised polyester powder
Paint colour	Yellow
Doors	1
Shelves (including base)	2
Shipping weight	65kg

MANUFACTURED TO MEET THE REQUIREMENTS OF		
AS2714-2008	The storage and handling of organic peroxides	
AS1319-1994	Safety signs for the occupational environment	
ADG CODE 7.6	Australian Dangerous Goods Code 2018 Edition 7.6	
AS4506-2005	Metal finishing - Thermoset powder coatings	

DIMENSIONS (W x D x H)		
External dimensions	595mm x 475mm x 1005mm	
Internal dimensions	500mm x 375mm x 754mm	



### Class 3: Flammable Liquids

Flammable liquids are liquids, or mixtures of liquids, or liquids containing solids in solution or suspension (for example, paints, varnishes, lacquers, etc., but not including substances otherwise classified on account of their dangerous characteristics) which give off a flammable vapour at temperatures of not more than 60 °C, closed-cup test, or not more than 65.6 °C, open-cup test, normally referred to as the flash point.

Referenced from the Australian Dangerous Goods Code, 2017, Edition 7.5